

- 1. ON ALL CURB RETURNS A 1/2" EXPANSION JOINT SHALL BE CONSTRUCTED BETWEEN THE BACK OF CURB AND THE SIDEWALK FOR THE ENTIRE LENGTH OF THE RETURN.
- 2. THE TYPE II AGGREGATE BASE THICKNESS IS SHOWN ON THE TYPICAL SECTION DRAWINGS 202 207.
- 3. LONGITUDINAL WEAKENED PLANE JOINT REQUIRED AT MIDPOINT OF SIDEWALK 10' OR WIDER.
- 4. WHEN INSTALLED WITHIN THE ROW, SIDEWALK GRADE IS PERMITTED TO EQUAL THE GENERAL GRADE ESTABLISHED FOR THE ADJACENT STREET OR HIGHWAY.
- 5. OBJECTS WITH LEADING EDGES MORE THAN 2.25 FT. AND NOT MORE THAN 6.7 FT. ABOVE FINISH SURFACE SHALL PROTRUDE 4 IN. MAXIMUM HORIZONTALLY INTO PEDESTRIAN CIRCULATION PATH. THE MINIMUM HEIGHT, MEASURED VERTICALLY FROM THE BOTTOM OF THE SIGN TO THE TOP OF SIDEWALK, OF SIGNS INSTALLED ABOVE SIDEWALKS, SHALL BE 7 FT.
- 6. PEDESTRIAN ACCESS ROUTE SHALL HAVE A CROSS SLOPE OF NO GREATER THAN 2%, REGARDLESS OF CONSTRUCTION TOLERANCES.

		AGENCY APPRO	JVED	В	C	Н	L	IVI	N	R
SPECIFICATION REFERENCE		UNIFORM STANDARD DRAWINGS CLARK COUNTY AREA								
302	AGGREGATE BASE	SIDEWALK								
501	CONCRETE									
502	CONCRETE STRUCTURES									
707	JOINT MATERIAL									
•		DATE 01-09-20	DWG.	NO. 2	234					