



## SECTION A-A

## NOTES:

- 1. CONCRETE COLLAR TO BE CONSTRUCTED 1/8" BELOW SURFACE OF DENSE GRADE WHERE OPEN GRADE IS NOT USED.
- 2. CONCRETE COLLAR NOT REQUIRED IN UNINCORPORATED CLARK COUNTY RESIDENTIAL STREETS LESS THAN 80' R/W WIDTH.
- 3. THE USE OF 30" RING AND COVER SHALL BE APPROVED BY THE ENTITY ENGINEER.
- 4. WHEN INSTALLED WITHIN PEDESTRIAN ACCESS ROUTES, TOP OF MANHOLE COVERS SHALL HAVE NO VERTICAL SURFACE DISCONTINUITIES GREATER THAN 1/4" WITH ADJACENT SURFACE, HAVE NO GAPS GREATER THAN 1/2" REGARDLESS OF CONSTRUCTION TOLERANCES, AND BE FIRM, STABLE, AND SLIP RESISTANT.

		AGENCY APPR	OVED	В	(C)	Н	L	М	N	R
SPECIFICATION REFERENCE		UNIFORM STANDARD DRAWINGS CLARK COUNTY AREA								
501	CONCRETE	CONCRETE COLLAR AROUND								
505	REINFORCING STEEL									
		MANHOLES								
		30 INCH RING AND COVER								
•		DATE 01-09-20	DWG.	NO. 4	08.1					