



- NOTES**
1. MINIMUM 28 DAY CONCRETE STRENGTH = 4500 PSI.
 2. LAP SPLICES OF REINFORCING STEEL SHALL BE 24". STAGGER LAP SPLICES A MINIMUM OF ONE LAP LENGTH.
 3. L, W, H, AND C PER PLAN.
 4. PARALLEL TO THE STREET OR HIGHWAY, THE GRADE OF THE BOARDING AND ALIGHTING AREA SHALL BE THE SAME AS THE STREET OR HIGHWAY, TO THE EXTENT PRACTICAL. PERPENDICULAR TO THE STREET OR HIGHWAY, THE GRADE OF THE BOARDING AND ALIGHTING AREA SHALL NOT BE GREATER THAN 2%, REGARDLESS OF CONSTRUCTION TOLERANCES.

SPECIFICATION REFERENCE		AGENCY APPROVED	B	C	H	L	M	N	R
302	AGGREGATE BASE	UNIFORM STANDARD DRAWINGS CLARK COUNTY AREA							
501	CONCRETE								
502	CONCRETE STRUCTURES	BUS SHELTER PAD DETAILS AND NOTES							
		DATE 01-09-20	DWG. NO. 234.5						