



NOTES

1. IF WIDTH OF PLATE IS GREATER THAN 24", A SPECIAL DESIGN IS REQUIRED.
2. ALL EXPOSED METAL PARTS SHALL BE GALVANIZED, AND ALL GALVANIZING DAMAGED BY FABRICATION OR INSTALLATION SHALL RECEIVE TWO COATS OF ALUMINUM PAINT (GALVONOX OR EQUAL). EXPOSED METAL PARTS IN THE PEDESTRIAN ACCESS ROUTE SHALL BE FIRM, STABLE, AND SLIP-RESISTANT.
3. TACK WELDS BETWEEN SIDEWALK AND STEEL PLATE FLOOR WITHIN PEDESTRIAN ACCESS ROUTES SHALL HAVE NO VERTICAL SURFACE DISCONTINUITIES GREATER THAN 1/4", REGARDLESS OF CONSTRUCTION TOLERANCES.

AGENCY APPROVED	B	C	H	L	M	N	R
UNIFORM STANDARD DRAWINGS CLARK COUNTY AREA							
SIDEWALK DRAIN							
DATE 08-10-23	DWG. NO. 236						

SPECIFICATION REFERENCE	
302	BASE AGGREGATES
501	CONCRETE
710	STRUCTURAL STEEL